

18-Jan-05

Stata Center Leaks Tracking Log

Leak #	Location	Date of Initial Marking	Skanska Comments	Completion Date	
1	280 lounge near TIG entrance	9/8/2004	Complete & Tested	9/17/2004	No Work Required
2	Outside G449 (Kiva) at top of Stair #8	9/8/2004	Complete & Tested	9/23/2004	No Work Required/ Metal Closure
3	Along D4 corridor, close to entrance to bldg 36	9/8/2004	Complete & Tested	9/17/2004	No Work Required/ Metal Closure
4	Dreyfoos 5 in front of the stairway #2 door	9/8/2004	Complete	9/24/2004	Drywall touch up and paint & replace Tecturn panel
5	Dreyfoos 5 against window near stairway #2 door	9/8/2004	Complete	9/24/2004	Drywall touch up and paint
6	Dreyfoos 6, corridor by helmet board room MISSING WINDOW	9/8/2004	Complete	9/27/2004	No Work Required
7	REOPEN - Stairway #8 from G449 (Kiva)	9/8/2004	Complete and Tested	10/5/2004	Drywall touch up and paint
8	Stair #7 from D463 (Star)	9/8/2004	Complete	9/23/2004	No Work Required/ Metal Closure
9	Stair #7 from D463 (Star), at catwalk doors (TGP)	9/8/2004	Complete	9/23/2004	No Work Required/ Metal Closure
10	REOPEN - Open area 331 (base of vertical light)	9/8/2004	Complete and Retested	10/5/2004	Stained ceiling tiles, carpet and drywall replaced and painted
11	Outside G966, over file cabinets	9/8/2004	Under Investigation		Drywall touch up and paint
12	REOPEN - Open area 235, by first main column near entrance	9/8/2004	Complete and Retested	10/5/2004	Stained ceiling tiles, carpet and drywall replaced and painted
13	Window outside 239; (East Twin vertical light)	9/8/2004	Complete and Retested	9/30/2004	Drywall touch up and paint
14	Office 257; leak coming out of window-washing anchor in ceiling	9/8/2004	Still Under Investigation		No Work Required
15	8th Flr Dreyfoos - Leak in light court southern end near column	9/8/2004	Complete and Retested	9/30/2004	Drywall touch up and paint
16	8th Flr Dreyfoos - in room 818 (curtain wall corner of Giraffe)	9/8/2004	Complete not Tested	9/16/2004	Drywall touch up and paint
17	Gates Office 630 - leak reported in ceiling	9/18/2004	Complete panels not tested	9/30/2004	Drywall touch up and paint
18	Nose 380 - Leak reported in the East windowbox at window frame	9/18/2004	Window needs to be resealed not yet complete		No Work Required
19	Achilles above Student Street (East Tiered)	9/18/2004	In progress repair not yet complete		Drywall replaced and painted
20	Gates office 488 leaks reported from testing of Achilles (leak #19)	9/27/2004	Complete and Tested	10/5/2004	Drywall touch up and paint
21	G484; leak in ceiling	9/28/2004	Complete and Tested	10/5/2004	Drywall touch up and paint
22	376; by main window, right side	9/28/2004	Under Investigation		Drywall touch up and paint
23	4th Flr Café at corner of R&D (Brick Horiz CW interface)	9/28/2004	Complete Resealed and Retested	9/30/2004	Stained carpet replaced
24	5th Flr Café at corner of R&D 2nd leak (Brick Horiz CW interface)	9/28/2004	Complete Resealed and Retested	9/30/2004	Stained carpet replaced
25	Inside door to terrace Star side	9/28/2004	Complete		No visible damage
26	Stairway #7 at Light Court spilt Purlin	9/28/2004	Complete not tested	10/5/2004	No Work Required/ Metal Closure
27	Star brick wall near elevator #12	9/28/2004	Reviewed with Karas		No Work Required/ Metal Closure
28	376; by main window, left side	9/28/2004	Reviewed with Karas		Drywall touch up and paint
29	Gates Lightcourt at intersection of Heart and Horiz. CW	9/28/2004	Complete not tested		No Work Required/ Metal Closure
30	G275 Light court under stair #8 (caused from Reopen leak #7)	9/28/2004	This leak is part of Leak #7		Drywall touch up and paint
31	Hallway to bldg 36, D4 roughlyly 4' from last one	9/29/2004	Complete not tested		No Work Required/ Metal Closure
32	Gates Main Entry alongside main stair in front of column	9/29/2004	Reviewed with Karas		No Work Required/ Metal Closure
33	Gates East Entry (Student St level) 2 locations	9/29/2004	Reviewed with Karas		Drywall touch up and paint
34	4th Flr Underfloor of Kiva	9/30/2004	Reviewed with Karas		No visible cosmetic damage
35	ChildCare leak at ramp skylight	9/29/2004	Reviewed with Karas		No visible cosmetic damage
36	Skylight of stair#1	9/8/2004	Complete	9/16/2004	Drywall touch up and paint
37	Biolab, by wall to stair#7	12/24/2004			
38	D450 lounge	1/5/2005			
39	G5 catwalk in R&D	1/14/2005			
40	backroom of Helmet	1/14/2005			
41	hallway outside helmet, 4 locations	1/14/2005			
42	right side of Pub along curved wall, 2 locations	1/14/2005			
43	Gates entrance, right of stair	1/14/2005			
44	near the union of kiva's panels and the rightside of the door jamb	1/19/2005			